

USA Ground Operations CIL Sheet

AUG 23 1999

Cal Item: Valve, Butterfly
 NASA Part No: None
 Mfg/Part No: Bray / 42-0300-11000-466
 System: Facility Water System

Criticality Category: 1S
 Total Quantity: 4

Find No.	Qty	Area	PMN	Baseline	Drawing / Sheet
A114420 (V-45)	1	Pad-A	K60-0045	007.00	79K06011 / 17
A114426 (V-44)	1	Pad-A	K60-0045	007.00	79K06011 / 17
A156593 (V-300)	1	Pad-A	K60-0045	007.00	79K06011 / 19
A156600 (V-301)	1	Pad-A	K60-0045	007.00	79K06011 / 19

Function:

Provide fire water flow to the spray nozzles for the associated area.

Failure Mode No. Failure Mode	Failure Cause Failure Effect	Detection Method Time to Effect	Crit Cat
09SY03A-001.015 Fail closed	Corrosion, contamination, or failure of internal piece part. Loss of fire water flow to the spray nozzles for the associated area. Possible loss of life and/or vehicle during a hazardous condition.	Valve position switch Immediate	1S

ACCEPTANCE RATIONALE

Design:

- Rated working pressure 675 psig.
- Actual working pressure 220 psig.
- Rated temperature (degrees Fahrenheit) -20 to 195.
- Actual temperature is ambient pad temperature.

Test:

- OMI M2067 requires cycling of FSS/RSS water valves to verify proper operation.
- OMRSD, File VI requires verification of the operational function of the water valve in all modes of operation semiannually and at replacement.

Inspection:

- OMI 6045 requires the inspection of the fire valves for signs of corrosion and/or contamination.

Failure History:

- Current data on test failures, unexplained anomalies, and other failures experienced during ground processing activities can be found in the PRACA database. The PRACA database was researched and no failure data was found on this component in the critical failure mode.
- The GIDEP failure data interchange was researched and no failure data was found on this component in the critical failure mode.

Operational Use:

Correcting Action	Timeframe
There is no action which can be taken to mitigate the failure effect.	Since no correcting action is available, timeframe does not apply.