

USA Ground Operations CIL Sheet

Critical Item: Valve, Check

Criticality Category: 1S

NASA Part No: None

Total Quantity: 1

Mfg/Part No: The Reliable Automatic Sprinkler Co / Model 4E

System: Facility Water System

Find No.	Qty	Area	PMN	Baseline	Drawing / Sheet
A526704 (V-566)	1	Pad-B	K61-3288-01	007.00	79K40021 / 7

Function:

Prevents ECLSS Support Station Firex water from flowing back into the water supply line.

Failure Mode No. Failure Mode	Failure Cause Failure Effect	Detection Method Time to Effect	Crit Cat
09SY03B-002.015 Fail Closed	Corrosion, contamination, or failure of internal piece part. Loss of firex water flow to the ECLSS Support Station. Possible loss of life and/or vehicle during a hazardous condition.	None Immediate	1S

ACCEPTANCE RATIONALE

Design:

- Rated working pressure 175 psig.
- Actual working pressure 160 psig.
- Rated temperature (degrees Farenheight) -20 to 100.
- Actual temperature is abient pad temperature.

Test:

- OMI 2088 requires confirmation of water flow through inspector's test valve to verify proper operation.
- OMRSD, File VI requires verification of system operational readiness semiannually and at component replacement.

Inspection:

Failure History:

- Current data on test failures, unexplained anomalies, and other failures experienced during ground processing activities can be found in the PRACA database. The PRACA database was researched and no failure data was found on this component in the critical failure mode.
- The GIDEP failure data interchange was researched and no failure data was found on this component in the critical failure mode.

Operational Use:

Correcting Action	Timeframe
There is no action which can be taken to mitigate the failure effect.	Since no correcting action is available, timeframe does not apply.