

240
 CRITICAL ITEMS LIST
 P/N: 28A7/1

NAME P/N QTY	COID	FAILURE MODE & CAUSE	FAILURE EFFECT	RATIONALE FOR ACCEPTANCE
RESERVE WATER P/N - ITEM 100 28A7502- 24 P1) 28A7-1	2/2	DEFINITION: BLADDER RUPTURE. CAUSE: EXCESSIVE CYCLING, DEFECTIVE MATERIAL, LACK OF FRYTON LUBRICATION.	EMERGENCY WATER LEAKAGE IN THE BLADDER AND CAVITY AND VENTILATION CIRCLES THROUGH THE ITEM 120 & RELIEF VALVE. GYS INTERFACE; FLOODING OF THE PLS ON ADDED GAS LEAKAGE AND VERY EXCESSIVE; LEAKAGE TO COMPLETE THE RECHARGE SEQUENCE. MISSION: LOSS OF USE OF ONE EMU. LEAKAGE TO RECHARGE. ENVIRONMENT: NONE.	A. DESIGN - THE CURRENT DESIGN OVERSEE TO MEMPHRE LATE WHICH ELEMENTS CHARACTERISTICS, ELASTICITY AND ELONGATION CHARACTERISTICS. BLADDER PROCESSING IS CONTROLLED TO PROVIDE UNIFORM PRODUCT PROPERTIES. THE HOUSING CAVITY WALLS CONSIST OF SMOOTH SURFACES. THE BLADDER IS LUBRICATED PRIOR TO BLADDER INSTALLATION. THE SIZE RATIO OF BLADDER TO CAVITY IS APPROX. 1 WHICH MINIMIZES BLADDER STRESSING. THE TANK STRUCTURE SUPPORTS THE LOAD WHEN THE INNER PRESSURE IS ABOVE THE GAS PRESSURE. B. TEST - COMPONENT ACCEPTANCE: THE ITEM IS HERMETICALLY LEAKAGE TESTED PER AT-E-118-2 BY PRESSURIZING THE ITEM AND TRICK TO PS.S - 15.7 PSID GMP. THE GY OUTLET IS CONNECTED TO A MOSE AND THE END OF THE MOSE SUBMERGED IN N2O. THERE SHALL BE NO BUBBLES THROUGH A 5 MINUTE PERIOD. A BLADDER COLLAPSE LEAKAGE TEST IS PERFORMED BY PRESSURIZING THE GY SIDE OF THE BLADDER TO 0.0 - 0.1 PSID GMP. WITH THE MID SIDE OF THE BLADDER CONNECTED TO A MOSE AND OUTLET OF THE MOSE SUBMERGED IN N2O. THE LEAKAGE SHALL BE LIMITED TO 1 BUBBLE IN 2 MINUTES. THE PRESSURE IS INCREASED TO 0.5 - 10.7 PSID GMP AND THE LEAKAGE SHALL BE THE SAME. PRESSURIZED TIME IS TRACKED PER THE LEMERD LETS LIST (28A7-67-000). PDA) A BLADDER COLLAPSE LEAKAGE TEST IS PERFORMED PER 28A7-67-010 BY PRESSURIZING THE BLADDER GY SIDE TO 10.4 - 15.7 PSID GMP. WITH THE MID SIDE OF THE BLADDER CONNECTED TO A MOSE AND THE MOSE SUBMERGED IN N2O. THE LEAKAGE SHALL NOT EXCEED 1 BUBBLE IN 2 MINUTES. A WATER CONTAIN LEAKAGE TEST IS PERFORMED BY PRESSURIZING THE WATER CIRCLES TO 10.7 - 08.9 PSID N2O. THE LEAKAGE SHALL NOT EXCEED 4 SCC/HR AS MEASURED WITH A VOLUMETRIC MEASUREMENT FOR A 60 MINUTE PERIOD.

28A7-67-010